ಪೊಲೀಸ್ ಮಹಾ ನಿರ್ದೇಶಕರ
ಹಾಗೂ ಮಹಾ ನಿರ್ದೇಶಕರು
ಕರ್ನಾಟಕ ರಾಜ್ಯ ಅಗ್ನಿಶಾಮಕ ಮತ್ತು ತುರ್ತು
ಸೇವೆಗಳು ಹಾಗೂ ರಾಜ್ಯ ವಿಪತ್ತು ಸ್ಪಂದನಾ
ಪಡೆಯ ನಿರ್ದೇಶನಾಲಯ
ನಂ.1 ಅಣ್ಣಾಸ್ವಾಮಿ ಮೊದಲಿಯಾರ್ ರಸ್ತೆ
ಬೆಂಗಳೂರು-560 042

ದೂರವಾಣಿ : 080 25570733
22971501
22971507

ಸಂಖ್ಯೆ:ಜಿಬಿಸಿ(2)446/2024
E-Office File No.1361/2025
E-Office Com No.67129.

ದಿನಾಂಕ:21-08-2025

ಗೆ,

ಶ್ರೀ ಎನ್. ದಿನೇಶ್ ಹೆಗ್ಡೆ
ಪ್ರಧಾನ ಕಾರ್ಯದರ್ಶಿ,
ರಾಷ್ಟ್ರೋತ್ಥಾನ ಪರಿಷತ್,
ಕೇಶವ ಶಿಲ್ಪ, ಕೆಂಪೇಗೌಡ ನಗರ,
ಬೆಂಗಳೂರು-560004.

ಮಾನ್ಯರೆ,

ವಿಷಯ:	ದಾವಣಗೆರೆ ಜಿಲ್ಲೆಯ ನಿಟುವಳ್ಳಿ ಇ.ಎಸ್.ಐ ಆಸ್ಪತ್ರೆ ಎದುರುಗಡೆ, ಡೋರ್ ನಂ.994/103 & ಸರ್ವೇ. ನಂ.103, 104/1ಬಿ, 105/1ಬಿ, 106/1ಬಿ & 107/1ಬಿ ಇಲ್ಲಿ ನಿರ್ಮಿಸಿರುವ ಮೆ|| ರಾಷ್ಟ್ರೋತ್ಥಾನ ವಿದ್ಯಾ ಕೇಂದ್ರ- ಸಿಬಿಎಸ್ಇ ಶೈಕ್ಷಣಿಕ ಕಟ್ಟಡಕ್ಕೆ ಸಮಾಪನ ಪತ್ರ ನೀಡುವ ಬಗ್ಗೆ.
ಉಲ್ಲೇಖ:	1) ಅಗ್ನಿಶಾಮಕ ಮತ್ತು ತುರ್ತು ಸೇವಾ ಇಲಾಖೆಯ ಅಗ್ನಿ ಸಲಹಾ ಪತ್ರ ಸಂ.ಜಿಬಿಸಿ(2)446/2023-24 ದಿನಾಂಕ:02-06-2025. 2) ನಿಮ್ಮ ಪತ್ರ ದಿನಾಂಕ:17-06-2025.

<<<<<<>>>>>>

ದಾವಣಗೆರೆ ಜಿಲ್ಲೆಯ ನಿಟುವಳ್ಳಿ ಇ.ಎಸ್.ಐ ಆಸ್ಪತ್ರೆ ಎದುರುಗಡೆ, ಡೋರ್ ನಂ.994/103 & ಸರ್ವೇ. ನಂ.103, 104/1ಬಿ, 105/1ಬಿ, 106/1ಬಿ & 107/1ಬಿ ಇಲ್ಲಿ ನಿರ್ಮಿಸಿರುವ 17.90 ಮೀಟರ್ ಎತ್ತರದ ನೆಲಹಂತ 04 ಮೇಲಂತಸ್ತು ಹೊಂದಿರುವ ಮೆ|| ರಾಷ್ಟ್ರೋತ್ಥಾನ ವಿದ್ಯಾ ಕೇಂದ್ರ-ಸಿಬಿಎಸ್ಇ ಶೈಕ್ಷಣಿಕ ಕಟ್ಟಡಕ್ಕೆ ಅಗ್ನಿಶಾಮಕ ಮತ್ತು ತುರ್ತು ಸೇವಾ ಇಲಾಖೆಯಿಂದ ದಿನಾಂಕ:02-06-2025 ರಂದು ನಿಮ್ಮ ಕೋರಿಕೆಯಂತೆ ಅಗ್ನಿ ಸಲಹಾ ಪತ್ರ ನೀಡಲಾಗಿದೆ.

ಉಲ್ಲೇಖ (2) ರ ನಿಮ್ಮ ಪತ್ರದಲ್ಲಿ, ಸದರಿ ಶೈಕ್ಷಣಿಕ ಕಟ್ಟಡದಲ್ಲಿ ಅಗ್ನಿಶಮನ ಉಪಕರಣಗಳ ಅಳವಡಿಕೆ ಕಾರ್ಯ ಮುಗಿದಿದ್ದು, ಅಗ್ನಿಶಾಮಕ ಮತ್ತು ತುರ್ತು ಸೇವಾ ಇಲಾಖೆಯ ಸಮಾಪನ ಪತ್ರ ನೀಡುವಂತೆ ಕೋರಿರುವಿರಿ.

ನಿಮ್ಮ ಕೋರಿಕೆಯಂತೆ, ಪ್ರಾದೇಶಿಕ ಅಗ್ನಿಶಾಮಕ ಅಧಿಕಾರಿ, ದಾವಣಗೆರೆ ವಲಯ, ಕರ್ನಾಟಕ ಅಗ್ನಿಶಾಮಕ ಮತ್ತು ತುರ್ತು ಸೇವೆಗಳು ರವರು ದಿನಾಂಕ:15-07-2025 ರಂದು ದಾವಣಗೆರೆ ಜಿಲ್ಲೆಯ

ನಿಟುವಳ್ಳಿ ಇ.ಎಸ್.ಐ ಆಸ್ಪತ್ರೆ ಎದುರುಗಡೆ, ಡೋರ್ ನಂ.994/103 & ಸರ್ವೇ. ನಂ.103, 104/1ಬಿ, 105/1ಬಿ, 106/1ಬಿ & 107/1ಬಿ ಇಲ್ಲಿ ನಿರ್ಮಿಸಿರುವ ಶೈಕ್ಷಣಿಕ ಕಟ್ಟಡವನ್ನು ಪರಿವೀಕ್ಷಣೆ ಮಾಡಿ ಅಗ್ನಿಶಾಮಕ ಮತ್ತು ತುರ್ತು ಸೇವಾ ಇಲಾಖೆಯು ನೀಡಿರುವ ಸಲಹಾ ಪತ್ರದಂತೆ, ಅಗ್ನಿರಕ್ಷಣೆ ಮತ್ತು ನಿಯಂತ್ರಣ, ಅಗ್ನಿನಂದಿಸುವ ಉಪಕರಣಗಳ ಅಳವಡಿಕೆ ಹಾಗೂ ರಕ್ಷಣಾ ಕ್ರಮಗಳನ್ನು ಶೈಕ್ಷಣಿಕ ಕಟ್ಟಡದಲ್ಲಿ ಪೂರ್ಣವಾಗಿ ಅನುಷ್ಠಾನಗೊಳಿಸಿರುವುದಾಗಿ ಹಾಗೂ ಸದರಿ ಕಟ್ಟಡದಲ್ಲಿನ ನೌಕರರು/ಸಿಬ್ಬಂದಿಗಳಿಗೆ ಅಗ್ನಿಶಮನ ಕುರಿತ ತರಬೇತಿ ಮಾತ್ರ ಬಾಕಿ ಇರುವುದಾಗಿ ಹಾಗೂ ಸದರಿ ಕಟ್ಟಡದ ಸಮಾಪನ ಪತ್ರ ತರುವಾಯ ಅದರಲ್ಲಿನ ಸಿಬ್ಬಂದಿಗಳಿಗೆ ಅಗ್ನಿಶಮನ ಕುರಿತ ತರಬೇತಿ ವ್ಯವಸ್ಥಿಸಲು ಸಾಧ್ಯವಾಗುತ್ತದೆಂದು ತಿಳಿಸಿರುತ್ತಾರೆ.

ಆದ್ದರಿಂದ, ದಾವಣಗೆರೆ ಜಿಲ್ಲೆಯ ನಿಟುವಳ್ಳಿ ಇ.ಎಸ್.ಐ ಆಸ್ಪತ್ರೆ ಎದುರುಗಡೆ, ಡೋರ್ ನಂ.994/103 & ಸರ್ವೇ. ನಂ.103, 104/1ಬಿ, 105/1ಬಿ, 106/1ಬಿ & 107/1ಬಿ ಇಲ್ಲಿ ನಿರ್ಮಿಸಿರುವ 17.90 ಮೀಟರ್ ಎತ್ತರದ ನೆಲಹಂತ 04 ಮೇಲಂತಸ್ತು ಹೊಂದಿರುವ ಮೆ|| ರಾಷ್ಟ್ರೋತ್ಥಾನ ವಿದ್ಯಾ ಕೇಂದ್ರ- ಸಿಬಿಎಸ್ಇ ಶೈಕ್ಷಣಿಕ ಕಟ್ಟಡಕ್ಕೆ ಅಗ್ನಿಶಾಮಕ ಮತ್ತು ತುರ್ತು ಸೇವಾ ಇಲಾಖೆಯ ಸಲಹಾ ಪತ್ರ ಸಂಖ್ಯೆ:ಜಿಬಿಸಿ(2)446/2023-24 ದಿನಾಂಕ:02-06-2025 ರಲ್ಲಿ ತಿಳಿಸಿರುವಂತೆ, ಅಗ್ನಿರಕ್ಷಣೆ ಮತ್ತು ನಿಯಂತ್ರಣ ಹಾಗೂ ಅಗ್ನಿನಂದಿಸುವ ಉಪಕರಣಗಳ ಅಳವಡಿಕೆ ಹಾಗೂ ರಕ್ಷಣಾ ಕ್ರಮಗಳನ್ನು ಕಟ್ಟುನಿಟ್ಟಾಗಿ ಪಾಲಿಸಬೇಕೆಂದು ಹಾಗೂ ನಿಮ್ಮ ದಿನಾಂಕ:01-08-2025 ಮುಚ್ಚಳಿಕೆ ಪತ್ರದಲ್ಲಿ ಒಪ್ಪಿರುವಂತೆ, ಅಗ್ನಿಶಮನ ಉಪಕರಣಗಳನ್ನು ಸುಸ್ಥಿತಿಯಲ್ಲಿಡಬೇಕೆಂಬ ಹಾಗೂ ಕಟ್ಟಡದಲ್ಲಿನ ಶೇಕಡಾ 40% ರಷ್ಟು ಸಿಬ್ಬಂದಿ/ನೌಕರರಿಗೆ ಅಗ್ನಿರಕ್ಷಣೆ ಮತ್ತು ನಿಯಂತ್ರಣ ಕ್ರಮಗಳ ಬಗ್ಗೆ ಬೆಂಗಳೂರಿನ ಆರ್.ಎ.ಮುಂಡ್ಕುರ್ ಅಗ್ನಿಶಾಮಕ ಮತ್ತು ತುರ್ತು ಸೇವೆಗಳ ಅಕಾಡೆಮಿಯಲ್ಲಿ ಸೂಕ್ತ ತರಬೇತಿಯನ್ನು 03 ತಿಂಗಳೊಳಗೆ ಪಡೆಯಲು ವ್ಯವಸ್ಥಿಸಬೇಕೆಂಬ ಷರತ್ತಿನ ಮೇಲೆ ಸಮಾಪನ ವರದಿ ಪ್ರಮಾಣ ಪತ್ರವನ್ನು ಅಗ್ನಿಶಾಮಕ ಮತ್ತು ತುರ್ತು ಸೇವಾ ಇಲಾಖೆಯಿಂದ ನೀಡಲಾಗಿದೆ.

ಈ ಸಮಾಪನ ಪ್ರಮಾಣ ಪತ್ರವು ಜಾರಿಯಾದ ದಿನಾಂಕದಿಂದ ಮುಂದಿನ ಎರಡು ವರ್ಷದವರೆಗೆ ಚಾಲ್ತಿಯಲ್ಲಿರುತ್ತದೆ. ತದನಂತರ ಈ ಸಮಾಪನ ಪ್ರಮಾಣ ಪತ್ರವನ್ನು ನವೀಕರಿಸುವಂತೆ ತಿಳಿಸಲಾಗಿದೆ.

ಹಾಗೆಯೇ ಒಂದು ವೇಳೆ ಯಾವುದೇ ಸಂದರ್ಭದಲ್ಲಿ ಇಲಾಖೆಯ ಶಿಫಾರಸಿನನ್ವಯ ಅಳವಡಿಸಿರುವ ಅಗ್ನಿನಿವಾರಣೆ ಹಾಗೂ ಅಗ್ನಿಶಮನ ಉಪಕರಣಗಳು ಸುಸ್ಥಿತಿಯಲ್ಲಿರದೇ ಇರುವುದು ಕಂಡು ಬಂದರೆ ಅಥವಾ ರಕ್ಷಣಾ ಕ್ರಮಗಳನ್ನು ಕಟ್ಟುನಿಟ್ಟಾಗಿ ಪಾಲಿಸದಿದ್ದರೆ ಅಥವಾ ಕಾನೂನಿನ್ವಯ ಸದರಿ ಕಟ್ಟಡದ ಸುತ್ತ ಬಿಟ್ಟಿರುವ ತೆರೆದ ಪ್ರದೇಶದಲ್ಲಿ ಯಾವುದೇ ಹೆಚ್ಚುವರಿ ರಚನೆಗಳನ್ನು ನಿರ್ಮಾಣ ಮಾಡಿದರೆ, ಅಥವಾ ಯಾವುದೇ ರೀತಿಯ ಖಾಯಂ/ತಾತ್ಕಾಲಿಕ ಅಡಚಣೆಗಳನ್ನು ಉಂಟು ಮಾಡಿದರೆ, ಈ 'ಸಮಾಪನ ಪ್ರಮಾಣ ಪತ್ರವು ಅನೂರ್ಜಿತಗೊಳ್ಳುವುದು ಹಾಗೂ ಕಾನೂನಿನ ಚೌಕಟ್ಟಿನಲ್ಲಿ ಮುಂದಿನ ಕ್ರಮ ಕೈಗೊಳ್ಳಲಾಗುವುದು ಎಂಬುದಾಗಿ ಸೂಚಿಸಲಾಗಿದೆ.

ತಮ್ಮ ವಿಶ್ವಾಸಿ,

ಡಿಜಿಪಿ & ಡಿಜಿ ರವರಿಂದ
ಕರಡು ಅನುಮೋದಿಸಲ್ಪಟ್ಟಿದೆ

Digitally signed by
T N SHIVASHANKARA
Date: 21-08-2025
17:50:24

(ಟಿ.ಎನ್.ಶಿವಶಂಕರ)
ನಿರ್ದೇಶಕರು
ಪೊಲೀಸ್ ಮಹಾ ನಿರ್ದೇಶಕರು
ಹಾಗೂ ಮಹಾ ನಿರ್ದೇಶಕರು
ಕರ್ನಾಟಕ ರಾಜ್ಯ ಅಗ್ನಿಶಾಮಕ ಮತ್ತು ತುರ್ತು
ಸೇವೆಗಳು
ರವರ ಪರವಾಗಿ

PRINCIPAL
Rashtrotthana Vidya Kendra
Aff. No-830511, Opp. ESI Hospital
Nittuvalli, DAVANGERE-577004.

SECRETARY
Rastrotthana Vidya Kendra
Nittuvalli, Davangere.

Director General of Police
and Director General
Karnataka State Fire and Emergency Services
and State Disaster Response Force (SDRF) Directorate
No. 1, Annaswamy Mudaliar Road, Bengaluru - 560 042

Number: GBC(2)446/2024
E-Office File No: 1361/2025
E-Office Com No: 67129.

Telephone: 080 25570733
22971501
22971507
Date: 21-08-2025

To,
Sri N. Dinesh Hegde
General Secretary,
Rashtrotthana Parishat, City,
Keshava Shilpa, Kempegowda Nagar,
Bengaluru - 560004.

Respected Sir,

Subject:	Regarding the issuance of a Clearance Certificate (NOC) for M/s Rashtrotthana Vidya Kendra - CBSE Educational Building consisting of Ground floor + 04 Upper floors with a height of 17.90 meters, constructed at Door No. 994/103 & Survey Nos. 103, 104/1B, 105/1B, 106/1B & 107/1B, Opposite E.S.I. Hospital, Nituvalli, Davanagere District.
Reference:	1) Fire Advice Letter No. GBC(2)446/2023-24 dated: 02-06-2025 issued by the Fire and Emergency Services Department. 2) Your letter dated: 17-06-2025.

As per your request, a Fire Advice Letter was issued by the Fire and Emergency Services Department on 02-06-2025 for M/s Rashtrotthana Vidya Kendra - CBSE Educational Building consisting of Ground floor + 04 Upper floors with a total height of 17.90 meters, constructed at Door No. 994/103 & Survey Nos. 103, 104/1B, 105/1B, 106/1B & 107/1B, Opposite E.S.I. Hospital, Nituvalli, Davanagere District.

In your letter cited under reference (2), you have requested the issuance of a Clearance Certificate (Final NOC) from the Fire and Emergency Services Department, stating that the installation of fire fighting systems and equipment in the said educational building has been completed.

In accordance with your request, the Regional Fire Officer, Davanagere Zone, Karnataka Fire and Emergency Services, inspected the educational building constructed at Door No. 994/103 & Survey Nos. 103, 104/1B, 105/1B, 106/1B & 107/1B, Opposite E.S.I. Hospital, Nituvalli, Davanagere District on 15-07-2025. Following the inspection, it was reported that fire prevention, control, and extinguishing systems along with other safety measures have been fully implemented in the educational building as per the advice letter issued by the Fire and Emergency Services Department. It was further mentioned that only fire fighting training for the employees/staff of the building is pending, and arranging this training will be feasible after the issuance of the

Official Translation. This is for informational purposes only. AI responses may include mistakes.

PRINCIPAL
Rashtrotthana Vidya Kendra
Aff. No-830511, Opp. ESI Hospital
Nittuvalli, DAVANGERE-577004.

SECRETARY
Rastrotthana Vidya Kendra
Nittuvalli, Davangere.

Clearance Certificate for the building.

Therefore, this Clearance Certificate (Final NOC) is issued by the Fire and Emergency Services Department for M/s Rashtrotthana Vidya Kendra - CBSE Educational Building consisting of Ground floor + 04 Upper floors with a height of 17.90 meters, constructed at Door No. 994/103 & Survey Nos. 103, 104/1B, 105/1B, 106/1B & 107/1B, Opposite E.S.I. Hospital, Nituvalli, Davanagere District, subject to the condition that fire prevention, control, extinguishing equipment, and safety measures must be strictly maintained as specified in the Department's Advice Letter No. GBC(2)446/2023-24 dated: 02-06-2025. Additionally, as agreed in your affidavit/undertaking letter dated: 01-08-2025, you must ensure that all fire fighting equipment is kept in good working condition and arrange for appropriate training on fire safety and management for at least 40% of the building's staff/employees at the R.A. Mundkur Fire and Emergency Services Academy in Bengaluru within 03 months.

This Clearance Certificate shall be valid for a period of two years from the date of its issuance. Thereafter, it must be renewed as directed.

Furthermore, it is advised that if at any point during inspections, the installed fire prevention and fire-fighting systems recommended by the department are found to be not in proper working condition, if safety measures are not strictly adhered to, or if any additional or illegal permanent/temporary structures are built or obstructions created in the open surrounding space required by law around the building, this Clearance Certificate shall stand cancelled/void, and further legal actions will be initiated within the framework of law.

Yours faithfully,

Draft Approved by DGP & DG

(T.N. Shivashankar)
Director
For Director General of Police
and Director General,
Karnataka State Fire and Emergency Services

Copy to: Regional Fire Officer, Davanagere Zone, Davanagere.

PRINCIPAL
Rashtrotthana Vidya Kendra
Aff. No-830511, Opp. ESI Hospital
Nittuvalli, DAVANGERE-577004.

SECRETARY
Rastrotthana Vidya Kendra
Nittuvalli, Davangere.

Official Translation. This is for informational purposes only. AI responses may include mistakes.