GM UNIVERSITY
P. B. Road Davanagere -577006
Department of Civil Engineering

To,
The Principal
Rashtrotthana Vidya Kendra
Opp ESI Hospital
Nittuvalli, Davanagere

Date: 18-09-2026

Ref No: GMTC / CES / 2026-27 / 50

Subject: Test Report of the Water Sample received from the Client
Date of sample collection: 17-09-2026
Date of Testing: 18-09-2026

Sl. No.	Parameter	Test Value	Required Acceptable Limits As per BIS 10500(2012) Indian Standard Specification For Drinking water	Required permissible Limits As per BIS 10500(2012) Indian Standard Specification For Drinking water
1	pH	7.40	6.5-8.5	No Relaxation
2	Total Dissolved Solids (TDS)	55 mg/l	500 mg/l	2000 mg/l
3	Electrical Conductivity (EC)	88.7 µS/cm	400 µS/cm	-
4	Total Hardness	52 mg/l	200 mg/l	600 mg/l
5	Calcium Hardness	42 mg/l	75 mg/l	200 mg/l
6	Chlorides	40 mg/l	250 mg/l	1000mg/l
7	Turbidity	1 NTU	1NTU	5NTU
8	Alkalinity	66 mg/l	200 mg/l	600 mg/l

Note: The above values are of the sample provided by the client only. This report is strictly confidential, it's use for publicity or arbitration in legal disputes is for bidden. The test results are valid for the sample collected and given on the above date only.

Comments:
The water sample was tested for the parameters listed above and compared with the requirements of BIS 10500:2012 for drinking water. According to the test results obtained, all the analysed parameters of the water sample supplied were found to be **well within the acceptable limits** specified by BIS 10500:2012. No further treatment is recommended for the parameters tested. Hence, based on the results of the analysed parameters, the water sample is **suitable for drinking and other domestic purposes.**

Consultant 18/9

Lead Consultant

HOD
Head of the Department
Department of Civil Engineering
GM University, Davanagere-577006

PRINCIPAL
Rashtrotthana Vidya Kendra
Aff. No-830511, Opp. ESI Hospital
Nittuvalli, DAVANGERE-577004.

SECRETARY
Rastrotthana Vidya Kendra
Nittuvalli, Davangere.

ಮಹಾನಗರಪಾಲಿಕೆ ಕಾರ್ಯಾಲಯ
ದಾವಣಗೆರೆ

CITY CORPORATION OFFICE,
DAVANAGERE

ಕೈಲ್ವೇ ನಿಲ್ದಾಣ ಎದುರು, ಪಿ. ಬಿ ರಸ್ತೆ, ದಾವಣಗೆರೆ - 577002, PH : 08192-252899,232008, FAX : 08192-252899
Email: itstaff_nlb_davanagere@yahoo.com, Web: http://www.davanagerecity.mrc.gov.in/

No: CCD/HS/S C/CR- /2024-25

Date: 05-03-2025

TO WHOM SO EVER IT MAY CONCERN

This is to certify that RASHTROTHANA VIDYA KENDRA, ESI Hospital Nittuvalli, Davanagere. Located at below mentioned address of Ward No: 28 has maintained good hygiene, clean, neat, sanitary facilities provided are good and pollution free atmosphere exits in and around the Schools premises. This is for information as per the letter dated: 07-02-2025.

05/03/2025

Assistant Executive Engineer (Env)
City Corporation, Davanagere.

To,
RASHTROTHANA VIDYA KENDRA,
ESI Hospital Nittuvalli,
Davanagere,

PRINCIPAL
Rashtrotthana Vidya Kendra
Aff. No-830511, Opp. ESI Hospital
Nittuvalli, DAVANGERE-577004

SECRETARY
Rastrotthana Vidya Kendra
Nittuvalli, Davangere.