



ಮಹಾನಗರಪಾಲಿಕೆ ಕಾರ್ಯಾಲಯ
ದಾವಣಗೆರೆ



CITY CORPORATION OFFICE,
DAVANAGERE



ರೈಲ್ವೆ ನಿಲ್ದಾಣ ಎದುರು, ಪಿ. ಬಿ. ರಸ್ತೆ, ದಾವಣಗೆರೆ - 577002, PH : 08192-252899, 232008, FAX : 08192-252899
Email: itstaff_ulb_davanagere@yahoo.com, Web: <http://www.davanagerecity.mrc.gov.in/>

No: CCD/HS/S C/CR- /2024-25

Date: 05-03-2025

TO WHOM SO EVER IT MAY CONCERN

This is to certify that RASHTROTHANA VIDYA KENDRA, ESI Hospital Nittuvalli, Davanagere. Located at below mentioned address of Ward No: 28 has maintained good hygiene, clean, neat, sanitary facilities provided are good and pollution free atmosphere exists in and around the Schools premises. This is for information as per the letter dated: 07-02-2025.


Assistant Executive Engineer (Env)
City Corporation, Davanagere.

To,
/ RASHTROTHANA VIDYA KENDRA,
ESI Hospital Nittuvalli,
Davanagere,



Srihate Educational Trust (R) Bheemasamudra

GM INSTITUTE OF TECHNOLOGY, DAVANGERE

Approved by AICTE | Affiliated by V.T.U Belagavi | Recognized by Govt. of Karnataka



DEPARTMENT OF CHEMISTRY

Date: 7th February, 2025

WATER ANALYSIS REPORT

Issued to : The Principal,
Rashtrottana Vidya Kendra,
Opp. ESI Hospital, Nituvalli
Davangere


Reference No. Your letter dated 05/02/2025

Sample received on : 6th February, 2025

Source of sample : Water sample from the campus

SAMPLE NOT DRAWN BY US

Sl. No	Parameters	Unit	ISI Limits	Result
1	pH	-	6.5 – 8.5	8.50
2	Conductivity	μ mhos/cm	-	1550.0
3	Total Dissolved Solids	mg/l	500 – 2000	914.6
4	Turbidity	NTU	0 - 10	0.0
Chemical Parameters				
5	Total Hardness as CaCO ₃	mg/l	300 – 600	578.0
6	Calcium as 'Ca'	mg/l	75 – 200	72.2
7	Chloride as 'Cl'	mg/l	250 – 1000	340.0


Head of the Department
Head of the Department
Department of Chemistry
GM Institute of Technology
DAVANGERE-577 006